

Basing Loss Prevention Recommendations on Risk

K. Gerry Phillips
Sr. Loss Prevention
Engineer

Introduction

- Recommendations arise from
 - » Underwriters
 - » Audit Teams
 - » Management
- Fail to consider the Risk
- NOVA Risk Management uses Quantitative Risk Analysis to evaluate

Single Facility or Scenario

- Recommendation aimed at single event
 - » Pool fire
 - » Jet Fire
 - » Explosion
- Can reduce frequency, probability, or consequences
- Calculate difference in expected loss

Example 1 - Single Area

- Fireproofing costing \$15,000
- Release frequency = 1 in 500 years
- Ignition probability = 1 in 5
- Damage for existing situation
 - » 95% - PD=\$90k; BI=90 days @ \$10k/day
 - » 5% - PD=\$25M; BI=16 mo @ \$10k/day
- Probable loss = \$2,430,500

Example 1 - continued

- Expected annual loss = \$972.20/year or about \$1000 per year
- Losses with fireproofing = negligible
- Probable savings = \$1000 per year
- Probable return on investment = $\$1000 \text{ per year} / \$15,000 = .067/\text{yr}$ or 6.7% per year.

Probable ROI for a Facility

- Recommendation affects total facility
- Expected losses must be calculated for each area for existing situation
- Calculation repeated with modification
- Expected savings are calculated
- Probable return on investment is calculated

Example 2 - Facility Study

- Recommended a third fire water supply pump
- Installed cost = \$200,000
- Reliability of existing pumps is .9
i.e. 1 failure per 10 demands
- Four units within the facility
- Liquid pool fires are the concern

Existing Situation Data

Area	Event Data		2 Pps Operate Prob. = 0.80		1 Pump Fails to Operate Prob. = 0.19		2 Pumps Fail to Operate Prob. = 0.01	
	Freq	Ign	PD (\$)	BI (\$)	PD (\$)	BI (\$)	PD (\$)	BI (\$)
Feed Prep	.05/yr	0.1	100k	100k	300k	500k	2M	10M
Reaction	.10/yr	0.05	500k	700k	900k	1000	4M	20M
Distillation	.10/yr	0.2	100k	100k	200k	300k	1M	20M
Prod Storage	.05/yr	0.05	50K	100k	100K	300k	.5M	20M

Probable Loss - Existing

Area	Expected Loss due to Fire (k\$)			Total Loss (\$)	Freq (fires/yr)	Probable Loss (\$/yr)
	2 Pumps Operate	1 Pump Operates	No Pumps Operate			
Feed Prep	160	152	120	432k	0.005	2,160
Reaction	960	361	240	1561k	0.005	7,805
Distillation	160	95	210	465k	0.02	9,300
Prod Storage	120	76	205	401k	0.0025	1,002
Total						20,267

Data for Modification

Area	Event Data		1 Pump Fails to Operate Prob. = 0.970		2 Pumps Fail to Operate Prob. = 0.029		3 Pumps Fail to Operate Prob. = 0.001	
	Freq	Ign	PD (\$)	BI (\$)	PD (\$)	BI (\$)	PD (\$)	BI (\$)
Feed Prep	.05/yr	0.1	100k	100k	300k	500k	2M	10M
Reaction	.10/yr	0.05	500k	700k	900k	1000	4M	20M
Distillation	.10/yr	0.2	100k	100k	200k	300k	1M	20M
Prod Storage	.05/yr	0.05	50K	100k	100K	300k	.5M	20M

Probable Loss - Modified

Area	Expected Loss due to Fire (k\$)			Total Loss (k\$)	Freq. (fires/yr)	Probable Loss (\$/yr)
	2 Pumps Operate	1 Pump Operates	No Pumps Operate			
Feed Prep	194	23.2	12	229.2	0.005	1,146
Reaction	1164	55.1	24	1243.1	0.005	6,216
Distillation	194	14.5	21	229.5	0.02	4,590
Prod Storage	145.5	11.6	20.5	177.6	0.0025	444
Total						12,396

Probable Return on Investment

- Probable annual loss - existing
=\$20,267/yr
- Probable annual loss - modified
=\$12,396/yr
- Potential savings = \$7,871/yr or
approximately \$8,000/yr
- Probable ROI = .04/yr or 4%/yr

Case Study - Nova Chemicals

- Recommended that Nova
 - » add a second diesel-driven pump
 - » install a supply from the county
- Installed cost of \$600,000
- Analysis addressed loss due to fire
- Considered 19 separate systems
- Used plant personnel for data

Case Study - Results

- The existing case represented an average loss of \$148k/yr
- The modified case produced an average loss of \$114k/yr
- Potential savings of \$34k/yr
- Probable rate of return of 6%
- The modifications could not be justified

Case Study - Other Concerns

- Potential failure of the water supply storage tank
- Major source of loss was from the compressor area due to poor drainage
- The deluge at the hexene storage bullet was designed for butene.

Case Study - Recommendations

- Do not install a second diesel-driven firewater pump.
- Install a larger supply from the MOEE
- Provide a by-pass around the water supply tank.
- Install drainage and holding facilities for lube oil spills in the compressor area.

Case Study - Recommendations

- Provide foam protection for the hexene storage area.
- Inspect the bottom of the firewater supply tank at the earliest opportunity.

Follow-up to the Study

- Expected frequency of complete electrical failure was 1 in 50 years when the original study was completed.
- Recent events have resulted in three complete power failures in 3 years.
- Expected losses will be significantly higher given the higher failure rate.
- What will be the result when the calculations are repeated?